

Drinking Water Quality and Compliance
Village of Elbow Distribution System
Station Number SK05HF0014
2015 Notice to Consumers

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the Village of Elbow Distribution System water quality and sample submission compliance record for the January 1, 2015 to December 31, 2015 time period. This report was completed on April 6, 2016. Readers should refer to the WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water in Saskatchewan, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

BACTERIOLOGICAL QUALITY

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	52	52	0
E. Coli	0 Organisms/100 mL	52	52	0
Background Bacteria	Less than 200/100 mL	52	52	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

WATER DISINFECTION

Chlorine Residual – From Test Results Submitted with Bacteriological Samples from Distribution System

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.1 mg/L	0.41 – 1.23	52	52	52
Total Chlorine	0.5 mg/L	0.55 – 1.47	52	52	52

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual **OR** 0.5 mg/L total chlorine residual is required at all times throughout the distribution system. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.

TURBIDITY

Turbidity – From Test Results Submitted with Bacteriological Samples from Distribution System

Parameter	Limit (NTU)	Range (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.11 – 0.37	52	52	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the "clarity" of the drinking water and is reported in Nephelometric Turbidity Units (NTU).

CHEMICAL – TRIHALOMETHANES (THM)

Trihalomethanes are formed when chlorine reacts with organic matter in water. The four THM compounds are: chloroform, dibromochloromethane, bromodichloromethane (BCDM) and bromoform. The sum of the concentrations of these four components is referred to as Total Trihalomethanes. The limit for THM is a long term objective based on an annual average of seasonal samples. Additional sampling was done for informational purposes only.

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Total Trihalomethanes	0.100	0.091	4	5

CHEMICAL – HALOACETIC ACIDS (HAAs)

Haloacetic acids are formed when chlorine reacts with organic matter in water. The five regulated haloacetic acids are: monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid. The sum of the concentrations of these five components is referred to as HAA5.

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Haloacetic Acids 5	No Standard	0.057	2	2

More information on water quality and sample submission performance may be obtained from:

Village of Elbow
Box 8
Elbow SK 06H 1J0
Phone: (306) 854-2277
Fax: (306) 854-2229
Email: info@elbowsask.com